



Buildings

LAA Permit Department of Buildings

Permit Number: **140568188-LAA**

Issued: **10/26/2016
5:21 PM**

Expires: **10/26/2017**

Address: **MANHATTAN 3604 BROADWAY**

Issued to: **THOMAS LORIA**

Floors: **BAS 001 thru 005**

Business: **GENUINE PLBG & HTG LLC**

Description of Work: **Plumbing: GAS PLUMBING WORK**

Licensee No: **P - 002174**

Gas Usage(s): Cooking

DUE TO LEAK & GAS SHUTDOWN TEST EXT'G GAS LINES FOR EXT'G STOVES IN (8) APTS #2S, 2N, 3S, 3N, 4S, 4N, 5S, 5N(FLS 2-5), METERS ARE EXT'G. INSTALL (1) 1" LOCKABLE VALVE ON EXT'G METER BAR IN BAS FOR APT 2N. FIRESTOPSNOT COMPROMISED. IN APTS 5N(5 FL), 3N(3 FL)& 2S(2 FL): REMOVE EXT'G 1/2" GAS VALVE & PIPE FROM STOVE, REPLACE APPROX 100'X 3/4" BLK PIPE SUPPLYING STOVE, SUPPLY & INSTALL NEW 3/4" GAS VALVE & GAS FLEX. DISCONNECT & CAP GAS LINE FOR DRYER. IN APTS 2N(2ND FL)& 5S(5TH FL), DISCONNECT & REMOVE EXT'G WASHER & DRYER, CAP OFF EXT'G 1/2" BLK PIPE, SUPPLY & INSTALL (1) 1/2" LOCKWING GAS VALVE. NO GAS PIPE IN HALL. A0317/7KP

Emergency Telephone Day or Night: **311**

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/20/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.