



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 140577828-LAA

Issued: 11/21/2016  
2:54 PM

Expires: 11/21/2017

Address: MANHATTAN 161 DUANE STREET

Issued to: ANTHONY M DISABATO

Floors: 005

Business: AMD & ASSOCIATES INC

Licensee No: F - 000356

Description of Work: *Fire Suppression: FIRE SUPPRESSION WORK*

*IN APARTMENT 5A ON THE 5TH FLOOR REARRANGE 16 CONCEALED RELIABLE G5 SPRINKLER HEADS WITHIN SAME ROOM USING APPROX 50' OF 1" BLACK PIPE. INSTALL 3 NEW RELIABLE G5 CONCEALED SPRINKLER HEADS USING APPROX 12' OF 1" BLACK PIPE. CAP AND REMOVE 1 CONCEALED SPRINKLER HEAD. THE SYSTEM WILL BE DRAINED AND OFFLINE FOR 1 DAY FOR THE DURATION OF 8 HOURS.*

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 05/02/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.