



Buildings



LAA Permit Department of Buildings

Permit Number: 140659990-LAA

Issued: 06/23/2017
8:20 AM

Expires: 06/23/2018

Address: MANHATTAN 53 W 105 STREET

Issued to: LOP K MOY

Business: FULL CIRCLE PLUMBING CORP

Floors: CEL

Licensee No: P - 002241

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Cooking

REPLACE APPROX. 25 LF OF EXISTING EXPOSED 3/4 GAS PIPING IN CELLAR FOR EACH RISER. RISERS FOR FLOORS 1,2,3,4,5.TOTAL OF 125 LF OF 3/4 GAS PIPING.ALL PIPING EXPOSED. USE EXISTING ANCHORS AND HANGERS.NO FIRESTOPPING COMPROMISED.NO ACP5 REQUIRED.ALL EXISTING VERTICAL PIPING AND STOVES TO REMAIN.PERFORM LOW PRESSURE GAS TEST.LABEL ALL NEW PIPING.CALL FOR DOB INSPECTIONS AS REQUIRED.EXISTING STOVES LOCATED IN UNITS 2,4,6,8,10.NO PIPING IN PUBLIC HALLWAYS.ALL PIPING IN CELLAR.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 03/29/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.