



Buildings



LAA Permit Department of Buildings

Permit Number: 140664859-LAA

Issued: 07/06/2017
11:50 AM

Expires: 07/06/2018

Address: MANHATTAN 140 BRADHURST AVENUE

Issued to: ROBERT J DWYER

Floors: CEL

Business: APPLIED PLUMBING SYS INC

Licensee No: P - 002051

Description of Work: *Plumbing: WATER PLUMBING WORK*

IN THE CELLAR WE WILL INSTALL 3 NEW SPRINKLER HEADS OFF OF THE DOMESTIC WATER LINE USING APPROXIMATELY 30' OF 1 1/2" PIPING. SPRINKLER SYSTEM WILL BE SHUTDOWN LESS THAN 8 HOURS. FDNY WILL BE NOTIFIED BEFORE AND AFTER SHUTDOWN. FIRESTOPS WILL NOT BE COMPROMISED.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 03/05/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.