




Buildings



LAA Permit Department of Buildings

Permit Number: 140671538-LAA

Issued: 07/20/2017
1:50 PM

Expires: 07/20/2018

Address: MANHATTAN 3809 BROADWAY

Issued to: ROSARIO GANGI

Floors: CEL

Business: MICHAEL GANGI P&H CONTRAC

Licensee No: P - 000220

Description of Work: *Plumbing: WATER PLUMBING WORK*

TO CHANGE 10 FEET OF 4'' BLACK PIPE FROM EXISTING WATER MAIN AND EXISTING OS&Y CONTROLL VALVE TO EXISTING 4'' DOUBLE DETECTOR CHECK VALVE, FEEDING SPRINKLER SYSTEM . FIRE STOPPING WILL NOT BE COMPROMISED AND THERE WILL BE NO PIPING IN PUBLIC AREARS.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 05/19/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.