



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 140719658-LAA

Issued: 11/27/2017  
1:26 PM

Expires: 02/21/2020

Address: MANHATTAN 330 SPRING ST

Issued to: JESSE A SKINNER

Floors: CEL

Business: SKINNER PLUMBING & HEATING

Licensee No: P - 001912

Description of Work: Plumbing: WATER PLUMBING WORK

INSTALLATION AT CELLAR OF 6" DCDA FOR THE FIRE SERVICE AND 4" RPZ DEVICE FOR THE DOMESTIC SERVICE. 6" AMES3000SS (MEA#66-03-E). 4" WATTS LF957 (MEA#66-03-E). DEVICES DRAIN VIA GRAVITY TO EXISTING FLOOR DRAIN.  
DEP APPROVAL NUMBER 16060379.  
R/A0219/9AS

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 01/01/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.