



Buildings

LAA Permit Department of Buildings

Permit Number: 140743480-LAA

Issued: 02/27/2018
11:26 AM

Expires: 02/27/2019

Address: MANHATTAN 220 WEST 107 STREET

Issued to: STEVEN BEHRENS

Floors: CEL

Business: HI-TECH HEATING CORP

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

Licensee No: O - 005401

CHANGE OF OIL GRADE FROM #4 TO #2, NO CHANGE IN USE, OCCUPANCY OR EGRESS UNDER THIS APPLICATION. ANTI-SYPHON VALVE AND SHUT OFF VALVE WILL BE INSTALLED ON THE EXISTING OIL LINE. THE PREHEATER WILL BE REMOVED. EXISTING EQUIPMENT FEDERAL FST 250 AND ICI DEG 105P NYC DEP APPLICATION # CA068993

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/20/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.