



Buildings



LAA Permit Department of Buildings

Permit Number: 140745031-LAA

Issued: 03/03/2018
2:40 PM

Expires: 03/03/2019

Address: MANHATTAN 25 CENTRAL PARK WEST

Issued to: PHILIP J KRAUS

Floors: 019

Business: FRED SMITH P&H CO INC

Licensee No: P - 000620

Description of Work: *Plumbing: WATER PLUMBING WORK*

LOCATED IN APT 19R, TO REPLACE EXISTING WATER RISER IN TWO AREAS, USING APPROX 30FT OF 4" COLD WATER, 20FT OF 1 1/2" HOT WATER AND 20FT 1" HW RETURN PIPING. PIPE, FROM LEAKING GALVANIZED PIPE TO TYPE-L COPPER PIPE. RECONNECT FROM EXISTING GALVANIZED PIPE WITH 4", 1 1/2" & 1" DIELECTRIC NIPPLE. REPLACED FOUR NEW BRANCH VALVES 3/4" AND RECONNECT TO EXISTING COPPER. FIRE STOP NOT TO BE COMPROMISED. ALL PIPE REPLACED IN SAME LOCATION.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 03/28/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.