



Buildings



LAA Permit Department of Buildings

Permit Number: 140749518-LAA

Issued: 03/20/2018
9:51 AM

Expires: 03/20/2019

Address: MANHATTAN 225 WEST 23RD STREET

Issued to: FRANK C BERNIE

Floors: CEL 005 thru 007

Business: KINGS PLAZA P & H INC

Licensee No: P - 000514

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Cooking

DUE TO UTILITY SHUT DOWN FOR LEAK ON METER WILL REPLACE EXISTING METER BAR WITH (3)UPDATED 250 METER BARS IN CELLAR FOR APT 5D, 6Q, 7H. WE WILL TEST GAS FROM (3) METERS IN CEL TO 7ST FL FOR STOVES IN APTS 5D ON 5TH FL, 6Q ON 6TH FL, 7H ON 7TH FL . APPLIANCES ON METERS:STOVES. NO GAS PIPE IN ANY PUBLIC HALLWAYS. FIRESTOPS WILL NOT BE COMPROMISED.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 08/19/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.