



Buildings



LAA Permit Department of Buildings

Permit Number: 140771886-LAA

Issued: 06/04/2018
11:06 AM

Expires: 06/04/2019

Address: MANHATTAN 6 WEST 77 STREET

Issued to: PHILIP J KRAUS

Floors: 016

Business: FRED SMITH P&H CO INC

Licensee No: P - 000620

Description of Work: *Plumbing: GAS PLUMBING WORK*

Gas Usage(s): Cooking

CON ED LOCKED METER TO PH-A, SCREW PIERCED RISER IN THE WALL IN APT 15A THAT IS SUPPLIES GAS FOR PH-A.TO REPAIR EXISTING RISER USING SECTION OF 1" BLK PIPE APPROX. 6FT OF PIPE WITH LEFT AND RIGHT.NIPPLE & COUPLING.TO REPLACE METER BAR IF REQUIRED BY CON ED SIZE 1" W/BYPASS VALVES IN CELLAR.TO REPLACE THE KITCHEN APPLIANCE VALVE 3/4" AND GAS FLEX SUPPLY TO STOVE.TO TEST FROM METER BAR IN CELLAR TO APPLIANCE VALVE IN PH-A.PIPE NOT IN PUBLIC AREA.FIRE STOP NOT TO BE COMPROMISED.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 03/30/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.