



Buildings



LAA Permit Department of Buildings

Permit Number: 140775720-LAA

Issued: 06/14/2018
3:51 PM

Expires: 06/14/2019

Address: MANHATTAN 6 WEST 77 STREET

Issued to: PHILIP J KRAUS

Floors: 015

Business: FRED SMITH P&H CO INC

Licensee No: P - 000620

Description of Work: *Plumbing: GAS PLUMBING WORK*

Gas Usage(s): Cooking

CON ED LOCKED METER IN CELLAR TO THE APT 15A/15FLR.TO REPLACE EXISTING GAS APPLIANCE VALVE IN KITCHEN AT THE EXIST'G STOVE SIZE 3/4"AND RECONNECT THE STOVE W/NEW APPROVED GAS FLEX.TO PRESSURE TEST EXIST'G GAS LINE FROM METER BAR ION CELLAR TO THE APPLIANCE VALVE IN THE KITCHEN.REPLACED SEC OF 3/4" BLACK PIPE 35FT FOR THE GAS BRANCH LINE W/NEW APPLIANCE VALVE 3/4".REPLACED GAS METER BAR PER CON ED IN CELLAR WITH 5FT OF GAS PIPING.ALL REPLACED BEFORE INSPECTIONS PER INSPECTOR COMMENTS.FIRESTOP NOT COMPROMISED. A0125/9DP

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 03/30/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.