



Buildings



LAA Permit Department of Buildings

Permit Number: 140787922-LAA

Issued: 07/26/2018
3:13 PM

Expires: 07/26/2019

Address: MANHATTAN 318 WEST 101 STREET

Issued to: JOSEPH R HOUSEL

Business: CHOSEN PLMBG & HTG CORP

Floors: CEL

Licensee No: P - 002410

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Heat

DUE TO LEAK & GAS SHUTDOWN REPLACE METER BAR FOR EXISTING METER & REPLACE APPROX 30' OF 2" & 40' OF 1 1/2" GAS PIPE IN CELLAR TO THE EXISTING STEAM BOILER THAT HAS TANKLESS COILS (122311382). FIRESTOPS WILL NOT BE COMPROMISED.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 07/17/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.