



Buildings

LAA Permit Department of Buildings

Permit Number: 140793372-LAA

Issued: 08/13/2018
11:28 AM

Expires: 08/13/2019

Address: MANHATTAN 545 WEST 148 STREET

Issued to: MICHAEL F SANTORO

Floors: CEL

Business: APPROVED OIL OF BKLYN, INC

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

Licensee No: O - 004219

WE WILL CHANGE THE FUEL GRADE FROM #4 TO #2. WE WILL REMOVE THE PRE-HEATER AND INSTALL AN ANTI-SIPHON VALVE FOR THE EXISTING EQUIPMENT. EXISTING BOILER: FEDERAL, MODEL: FST-80, UL MH16064, 3,360,000 BTU INPUT & EXISTING BURNER: INDUSTRIAL COMBUSTION, MMG-34P, UL MP1473, TO REMAIN. THERE IS NO CHANGE IN THE FIRING RATE. THE DEP APPLICATION # IS CS000618 & EXPIRES ON 8-16-2018.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/20/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.