



Buildings



LAA Permit Department of Buildings

Permit Number: 200404918-LAA

Issued: 12/19/1997

Expires: 12/19/1998

Address: BRONX 595 BRUCKNER BOULEVARD

Issued to: BARRY WEINTRAUB

Business: WEINTRAUB PLBG & MECH. SVC CORP

Floors: GRD, TH, RU, MEZ

Licensee No: P - 000633

Description of Work: *Plumbing: OTHER PLUMBING*

GROUND FL.,INSTALL 3-MODINE PD175 GAS FIRED UNIT HTGSBTU`S 175,000 MEA#293-96-E. HEATERS WITH FLUE VENTS THROUGH EXTENDEDABOVE ROOF. MEZZANINE, INSTALL 1-MODINE PD75 GAS FIRED UNIT HTG BTU`S 75,000MEA#293-96-E. HEATER WITH FLUE VENT THROUGH ROOF ABOVE MEZZANINE.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 02/23/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.