



Buildings



LAA Permit Department of Buildings

Permit Number: 200885550-LAA

Issued: 08/18/2005
12:23 PM

Expires: 08/18/2006

Address: BRONX 1210 CROES AVENUE

Issued to: HOWARD TUNE

Floors: BAS

Business: SEAVIEW PLUMBING INC

Licensee No: P - 001035

Description of Work: *Plumbing: OTHER PLUMBING*

PROVIDE 2 SPRINKLER HEADS WITHIN 5 FT OF LAUNDRY DRYER EQUIP. NEW 1" SPRINKLERLINE FROM EXISTING 2" SPRINKLER LINE PROTECTING COMPACTOR TRASH ROOM WITH 4HEADS.EXISTING SPRINKLER SYSTEM IN TAKEN OFF EXISTING DOMESTIC WATER SUPPLYLINE IN BASEMENT.BLDG CERT. OF OCC. INDICATES TENANT LAUNDRY ROOM AS PERM

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 03/05/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.