



Buildings

LAA Permit Department of Buildings

Permit Number: 200960308-LAA

Issued: 11/30/2006
3:14 PM

Expires: 11/30/2007

Address: BRONX 3764 BRONX BOULEVARD

Issued to: DOMINGO E VALERA

Floors: 001 thru 006

Business: DOVAL PLBG & HTG CORP

Description of Work: Plumbing: GAS EQUIPMENT/PIPING

Licensee No: P - 001316

Gas Usage(s): Cooking

THE REPLACEMENT OF THE GAS PIPING FROM THE METER TO COOKING STOVE.REPLACING 380 FT OF 3/4" BLK PIPE FOR APTS#1A,2A,3A,4A,5A,6A.INSTALL NEW CLASS 250 METER BARS & NEW CONTROL VALVES BEHIND STOVE.GAS CERTIFICATE REQUIRED BY UTILITY CO.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 02/02/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.