



Buildings



LAA Permit Department of Buildings

Permit Number: 200961156-LAA

Issued: 12/29/2006
7:25 PM

Expires: 12/29/2007

Address: BRONX 297 BROOK AVENUE

Issued to: LLOYD A JACKSON

Floors: BAS,001

Business: FOUR STAR MECHANICAL INC

Licensee No: P - 000859

Description of Work: Plumbing: GAS EQUIPMENT/PIPING

Gas Usage(s): Heat

TO INSTALL ONE MODINE, MEA #25-99-E, MODEL 60A-H0134 HEATER @ 60,000 BTUS USING APPROX. 50 FEET OF 3/4" BLACK PIPING. THIS EQUIPMENT IS VENTING THROUGH THE EXISTING CHIMNEY. ALSO A BLUE CARD WAS REQUIRED.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 05/23/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.