



Buildings



LAA Permit Department of Buildings

Permit Number: 210088867-LAA

Issued: 08/20/2008
10:04 AM

Expires: 08/20/2009

Address: BRONX 514 EAST 138 STREET

Issued to: IRVING BAUER

Floors: CEL

Business: G BAUER INC

Licensee No: 0 - 005163

Description of Work: oil: OIL TANK

REPLACE BOILER (NYC#16790-01) & OIL BOILER & CONNECT TO EXISTING MASONRY ATCHIMNEY IN CELLAR. EMERGENCY INSTALLATION PER 99N7/99 ALT II & 2ND FEE BY P.E.WITHIN 60 DAYS. ICI BURNER MEA#159-74-E MDL# MEG-34. ACTUAL BOILER BTU'S:3,360,000 INPUT 2,678,000 OUTPUT. ESTIMATED COST \$3000. (2008)

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 05/23/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.