



Buildings



LAA Permit Department of Buildings

Permit Number: 210127575-LAA

Issued: 09/23/2009
4:20 PM

Expires: 09/23/2010

Address: BRONX 3451 KNOX PLACE

Issued to: ALAN E ROSENBERG

Floors: BAS,005

Business: ALAN E. ROSENBERG, INC.

Licensee No: P - 000599

Description of Work: Plumbing: GAS EQUIPMENT/PIPING

Gas Usage(s): Cooking, Boiler Pilot

REPLACE LEAKING SECTION OF OVERHEAD GAS MAIN AT HEAD OF SERVICE & TESTED OVERHEAD RISERS & BRACHES (54 APTS) & GAS PILOT LIGHT TO BOILER. 50' X 3" BLK STEEL PIPE. (GAS CARD REQ)

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/21/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.