



Buildings



LAA Permit Department of Buildings

Permit Number: 210150352-LAA

Issued: 01/30/2012
3:51 PM

Expires: 01/30/2013

Address: BRONX 2766 UNIVERSITY AVENUE

Issued to: AUSENCIO H SANTOS

Floors: BAS,003

Business: DORIAN MECH SOLUTIONS CO

Licensee No: P - 002104

Description of Work: *Plumbing: GAS EQUIPMENT/PIPING*

Gas Usage(s): Cooking

GAS IS TURNED OFF BY CON ED BECAUSE OF A LEAK. REPLACE LEAKING GAS COCK BEHIND STOVE AND REPLACE DEFECTIVE METER BAR WITH A NEW CLASS 250 METER BAR & PERFORM INTEGRITY TEST. GAS USAGE IS COOKING. BLUE CARD IS REQUIRED. SUPERSEDING LETTER ATTACHED. 0119GH

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 05/25/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.