




**Buildings**



# LAA Permit Department of Buildings

Permit Number: 210151501-LAA

Issued: 03/07/2012  
11:02 AM

Expires: 03/07/2013

Address: BRONX 226 WILLIS AVENUE

Issued to: MICHAEL A MANISCOLCO

Floors: CEL

Business: APPROVED ENERGY LLC

Licensee No: P - 001679

Description of Work: Plumbing: OIL TO GAS CONVERSION

Gas Usage(s): Heat, Other

EMERGENCY REF#7544. EXISTING BOILER TO REMAIN(PEERLESS BOILER, MDL ECT-6, INPUT 385,000 BTUS, OUTPUT 321,000 BTUS, MEA#182-94-E. CONNECTED TO THE EXISTING CHIMNEY. TO INSTALL ONE REPLACEMENT BURNER(CARLIN BURNER, MDL#201-GAS MEA#137-0 5-E). TO INSTALL APPROX 50' OF 1 1/2" GAS PIPING AND ONE NEW METER BAR FOR HEAT AND HOT WATER ONLY. ACP5 CAI#117202. 0301RA

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 05/23/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.