



Buildings



LAA Permit Department of Buildings

Permit Number: 210160172-LAA

Issued: 10/18/2012
11:07 AM

Expires: 10/18/2013

Address: BRONX 2144 BRONX PARK EAST

Issued to: ROBERT FLAMENBAUM

Floors: BAS

Business: COMBUSTION CONSULT SVCS

Licensee No: 0 - 004207

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

CHANGE GRADE OF FUEL FROM #6 OIL TO #4 OIL. REMOVE SIDE ARM OIL PREHEATER FROM THE PREMISES. INSTALL ANTISYPHON VALVE AND SHUT OFF VALVE. DEP #CA056578X. ROCKMILLS 98-71E MP 125 1 BOILER 5,102,900BTU 10000 GALLON FUEL OIL TANK. EXISTING BOILER.

0910TM/1015PM

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 03/30/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.