



Buildings



LAA Permit Department of Buildings

Permit Number: 210175335-LAA

Issued: 03/11/2013
4:03 PM

Expires: 03/11/2014

Address: BRONX 514 EAST 138 STREET

Issued to: ALAN E ROSENBERG

Business: ALAN E. ROSENBERG, INC.

Floors: CEL

Licensee No: P - 000599

Description of Work: *Plumbing: GAS EQUIPMENT/PIPING*

Gas Usage(s): Heat, Other

INSTALL NEW GAS SERVICE, GAS METER AND APPROXIMATELY 80FT OF 3INCH GAS PIPING AND CONNECT TO EXISTING GAS/OIL BURNER: ICI MEG-34P, MEA# 159-74-E, NYC BOILER# MD16790-01 (BOILER: FEDERAL FST-80, MEA# 173-77-E, INPUT: 3,360,000 BTU/HR) FILED UNDER APPLICATION# 210064026. NO OIL WORK DONE UNDER APPLICATION GAS WORK ONLY. FIRESTOPS ARE NOT COMPRIMISED BY THIS WORK.

0305AR

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 05/23/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.