



Buildings

LAA Permit Department of Buildings

Permit Number: 220180854-LAA

Issued: 10/22/2015
6:51 PM

Expires: 10/22/2016

Address: BRONX 179 EAST MOSHOLU PARKWAY NORTH

Issued to: HENRY W TRAKTMAN

Floors: 001

Business: METROPOLITAN HEAT & POWER

Description of Work: Plumbing: GAS PLUMBING WORK

Licensee No: P - 001341

Gas Usage(s): Heat

REPAIR LEAK ON EXISTING GAS LINE LOCATED BETWEEN EXISTING GAS COCK AND EXISTING GAS TRAIN. BOILER/GAS BURNER INSTALLED AND SIGNED OFF ON LAA 220274343 ON 2/2/2015. THIS REPAIR FOR HPD. LEAK IS BETWEEN EXISTING GAS COCK AND PILOT GAS VALVE, ONE 1/4" ELBOW TO BE REPLACED

TEST GAS LINE TO BOILER. NO GAS AUTHORIZATION REQUIRED. 0804/5HPDB/1002/5HPDGREG

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/19/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.