



Buildings

LAA Permit Department of Buildings

Permit Number: 220187955-LAA

Issued: 08/22/2016
8:08 PM

Expires: 08/22/2017

Address: BRONX 3440 GATES PLACE

Issued to: KEITH R CAPPUCCIO

Floors: CEL

Business: DMT PLUMBING&HEATING CORP

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

Licensee No: O - 005355

CHANGE GRADE OF FUEL FROM #6 TO #2. NO CHANGE IN FIRING RATE. A PRE-HEATER WILL BE REMOVED AND AN ANTI SYPHON VALVE WILL BE INSTALLED. DEP INSTALLATION #CA117392.

0729/6VG*

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/23/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.