



Buildings

LAA Permit Department of Buildings

Permit Number: 220188570-LAA

Issued: 12/09/2016
3:52 PM

Expires: 12/09/2017

Address: BRONX 506 BROOK AVENUE

Issued to: EDWIN J LEMANSKI

Floors: BAS

Business: BALTER LEHIGH P&H CORP

Description of Work: Plumbing: GAS PLUMBING WORK

Licensee No: P - 000239

Gas Usage(s): Heat, Water Heater

REGISTER REPLACEMENT BOILER AND 75 GALLON HWH IN BASEMENT. REPIPE METER/REPIPE.
APPROX.50FT-60FT OF 1 1/2" GAS PIPING FROM METER IN BSMT. SUPPLYING BOILER AND HWH IN
BOILER ROOM.(1)METER SUPPLYING BOILER AND HWH ONLY. VENT THROUGH EXISTIN CHIMNEY.NO PIPING
IN PUBLIC AREAS.PIPE EXPOSED.METER EXISTING.BOILER FILED UNDER JOB#200607218 ONE
(1)BOILER,ONE (1)HOT WATER HEATER ON PREMISES CAP AND REMOVE THE 2ND HWH.NO COOKING ON
THIS METER.

1026/6HPD_1205/6HPDGREG

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/24/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.