



Buildings

LAA Permit Department of Buildings

Permit Number: 220274343-LAA

Issued: 11/25/2014
7:54 PM

Expires: 11/25/2015

Address: BRONX 179 EAST MOSHOLU PARKWAY NORTH

Issued to: REED D RICKMAN

Floors: CEL

Business: APEX MECHANICAL CORP

Description of Work: Plumbing: GAS EQUIPMENT/PIPING

Licensee No: P - 000649

Gas Usage(s): Heat

IN CELLAR GAS-GAS DIRECT REPLACEMENT WEIL McLAIN LGB-6 780,000 BTUS-624,000 OUTPUT VENTED THRU BRICK- TERA COTA LINED CHIMNEY CLASS 6853-01 FILE#112973_0_000 ALSO REPLACE 1 INCH GAS COCK & INSTALL APPX 1FT OF 1 INCH GAS PIPE- NO FIRESTOPPS COMPROMISED- NO GAS PIPE INSTALLED IN PUBLIC HALLWAYS *1029GM

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/19/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.