



Buildings



LAA Permit Department of Buildings

Permit Number: 220277395-LAA

Issued: 05/01/2015
8:46 AM

Expires: 05/01/2016

Address: BRONX 955 BRUCKNER BOULEVARD

Issued to: DAVID M WAGNER

Floors: BAS

Business: F&S PETROLEUM CORP

Licensee No: 0 - 002730

Description of Work: oil: OIL WORK

REPLACE DEFECTIVE BOILER IN BASEMENT, INSTALL NEW PEERLESS ECT-5 STEAM BOILER RATED @ 280,000 BTU @ 15 PSI NEW BECKETT AFG OIL BURNER VENTING TO EXISTING CHIMNEY. INSTALL 2 REPLACEMENT 275 GALLON HEATING OIL STORAGE TANKS IN LOCATION AS PREVIOUSLY EXISTED.

0330GREGHPD

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 11/17/2024 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.