



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 220310349-LAA

Issued: 07/14/2014  
8:40 AM

Expires: 07/14/2015

Address: BRONX 3442 JEROME AVENUE

Issued to: RAYMOND AGOSTO

Business: BRUCKNER PLUMBING LTD

Floors: CEL

Licensee No: P - 001178

Description of Work: *Plumbing: PRIMARY BACKFLOW PREVENTER (RPZ)*

*INSTALL (1)2" WATTS 009 RPZ MEA #43-95-M AND (1) 4" WILKINS 350-ADA DCDA  
MEA #221-04-M-VOL 2 IN THE CELLAR. CONNECT TO EXISTING SERVICE. DEP APPROVAL #13048428.  
FLOOR DRAIN IS EXISTING.*

0602GS

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 05/27/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.