



Buildings



LAA Permit Department of Buildings

Permit Number: 220319634-LAA

Issued: 03/07/2018
11:47 AM

Expires: 03/07/2019

Address: BRONX 1160 CROMWELL AVENUE

Issued to: GEORGE S BATEMAN

Floors: CEL,001,002

Business: GSB PLUMBING & HEATING CO

Licensee No: P - 002413

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Cooking

EWN15585_GAS WAS SHUT DOWN DUE TO ILLEGAL TEE& SECONDARY GAS SHUT OFF VALVE BEHIND THE EXISTING STOVE IN APT# 2B ON THE 2ND FL. STOVE REMOVE ILLEGAL TEE & SECONDARY VALVE LEAVING THE ORIGINAL GAS VALVE FOR STOVE IN PLACE& TEST EXISTING GAS LINE. FOR COOKING USE ONLY. (METER IS EXISTING). FIRESTOPS WILL NOT BE COMPROMISED.

0223/8VG*

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 11/20/2024 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.