




Buildings



LAA Permit Department of Buildings

Permit Number: 220372736-LAA

Issued: 06/02/2016
11:47 AM

Expires: 06/02/2017

Address: BRONX 930 SHERIDAN AVENUE

Issued to: PATRICK P CALABRO

Floors: CEL

Business: PROACTIVE PLBG & MECH. CO

Licensee No: P - 002178

Description of Work: Plumbing: WATER PLUMBING WORK

INSTALL (1) 4" WILKINS 375A MEA#6-99-M RPZ & (1) 6" WILKINS 350DA MEA#147-99-` M DCDA IN CELLAR. CONNECT TO EXISTING SERVICES. DEP APPROVAL #16061391. INSTALL FLOOR DRAIN & RUN APPROX 10' OF 3" NO HUB PIPE.

0526/6VG

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 11/26/2025 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.