



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 220373986-LAA

Issued: 03/06/2017  
9:46 AM

Expires: 03/06/2018

Address: BRONX 3505 BRUCKNER BOULEVARD

Issued to: MICHAEL A WIDING

Floors: CEL

Business: ALL HOUR SEWER SERVICE CO

Licensee No: P - 000835

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Cooking

IN CELLAR INSTALL 1 NEW METER FOR 3RD FLOOR APT USING APPROX 3FT OF 3/4" GAS PIPING.  
REPLACE 3/4 GAS VALVE WITH FLEX BEHIND 3RD FL STOVE. WILL TEST GAS FROM METER TO 3RD FL  
STOVE. APPLIANCE ON METER; (3RD FL STOVE). NO GAS PIPING IN PUBLIC HALLWAYS, FIRESTOP AS  
PER NYC CODE

0127/7DK

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 03/28/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.