



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 220376723-LAA

Issued: 12/29/2017  
5:40 PM

Expires: 12/29/2018

Address: BRONX 530 EAST 138 STREET

Issued to: DANIEL G MISA

Business: MISA PLUMBING, LLC

Floors: CEL

Licensee No: P - 000225

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Heat, Other

EWN15051\_DUE TO LEAK & GAS SHUTDOWN TEST EXISTING GAS LINE FOR EXISTING HEAT, HW COIL & GAS BOOSTER PUMP (#220329062). REPLACE APPROX 2' OF 4" GAS PIPING & FITTINGS BETWEEN THE EXISTING GAS METER & BOOSTER PUMP IN CELLAR. FIRESTOPS WILL NOT BE COMPROMISED. (BOILER PREVIOUSLY FILED UNDER #210011725) UTILITY RESTORED GAS ON 12/15 AT 2:30PM. GAS AUTHORIZATION NOT REQUIRED FROM DOB.

1221/7AP

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 05/23/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.