



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 240019494-LAA

Issued: 02/13/2013  
1:57 PM

Expires: 02/13/2014

Address: BRONX 217 ST ANNS AVE

Issued to: AHMET T SANGIRAY

Floors: CEL

Business: P.S.I. MECHANICAL

Licensee No: P - 001790

Description of Work: Plumbing: OIL TO GAS CONVERSION

Gas Usage(s): Heat, Water Heater

PIPING IS APPROX 80' OF 2 PIPE & 20' OF 3 1/4" PIPE FROM METER BAR TO BOILER & HWH.

(1) WEIL MCLAIN MODEL 680, MEA# 183-93-E V/II, 787 CFH IP 476 CFH OP & (1) AO SMITH BT80 DOMESTIC HWH @ THE CELLAR. BOILER & HWH VENTED THRU EXISTING CHIMNEY. ALL PL INSPECTIONS COMPLETE ON PREV FILING. NO FIRE STOPS COMPROMISED.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 05/23/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.