



Buildings

LAA Permit Department of Buildings

Permit Number: 240029937-LAA

Issued: 07/09/2013
1:09 PM

Expires: 07/09/2014

Address: BRONX 615 E168 STREET

Issued to: DOV M TRAUM

Floors: CEL

Business: DMT PLUMBING & HEATING CO

Description of Work: Plumbing: GAS EQUIPMENT/PIPING

Licensee No: P - 002157

Gas Usage(s): Heat, Other

INSTALL NEW METER BAR AND RUN APPROX. 30' OF 4" BLACK PIPE AND APPROX. 15' OF 21/2" BLACK PIPE TO EXISTING DUAL FUEL BURNER IC DEG 42-P. BOILER IS FEDERAL FST-100 (4,200,000 BTU). EXISTING EQUIPMENT FILED UNDER APPLICATION #200233336.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/21/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.