



LAA Permit Department of Buildings

Permit Number: 240030284-LAA

Issued: 07/11/2013
10:39 PM

Expires: 07/11/2014

Address: BRONX 3510 DECATUR AVENUE

Issued to: DOUGLAS SIMMONS

Business: DOUGLAS SIMMONS

Licensee No: O - 005335

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

CHANGE GRADE OF OIL FROM #6 TO #4 THERE IS NO CHANGE IN FIRING RATE. INSTALL ANTI-SIPHON
VALVE AND REMOVE HEATER DEP INSTALLATION CA084595X

Emergency Telephone Day or Night: 311

Borough Commissioner:

A handwritten signature of the Borough Commissioner.

Commissioner of Buildings:

A handwritten signature of the Commissioner of Buildings.

This permit copy created on 01/20/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.