



**Buildings**

# **LAA Permit Department of Buildings**

Permit Number: **240044457-LAA**

Issued: **12/10/2013  
3:21 PM**

Expires: **12/10/2014**

Address: **BRONX 1806 VYSE AVENUE**

Issued to: **BERNARD BAUER**

Floors: **CEL**

Business: **G. BAUER, INC**

Licensee No: **O - 005353**

Description of Work: **oil: OIL WORK - FUEL GRADE CHANGE**

**CHANGE FUEL GRADE FROM #6 TO #4. A PRE-HEATER WILL BE REMOVED AND AN ANTI-SYPHON VALVE FOR EXISTING EQUIPMENT WILL BE INSTALLED. THERE IS NO CHANGE IN FIRING RATE. DEP INSTALLATION #CA170887Z.**

Emergency Telephone Day or Night: **311**

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 01/21/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.