



LAA Permit Department of Buildings

Permit Number: 240044929-LAA

Issued: 12/17/2013
11:44 AM

Expires: 12/17/2014

Address: BRONX 3041 HOLLAND AVENUE

Issued to: BERNARD BAUER

Floors: CEL

Business: G. BAUER, INC

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

Licensee No: O - 005353

CHANGE FUEL GRADE FROM #6 TO #4. A PRE-HEATER WILL BE REMOVED AND AN ANTI-SYPHON VALVE FOR EXISTING EQUIPMENT WILL BE INSTALLED. THERE IS NO CHANGE IN FIRING RATE. DEP INSTALLATION #CA246785X. ACP5 FILED UNDER #220025639.

Emergency Telephone Day or Night: 311

Borough Commissioner:

A handwritten signature in black ink, appearing to read 'John J. ...'.

Commissioner of Buildings:

A handwritten signature in black ink, appearing to read 'Craig R.'.

This permit copy created on 01/22/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.