



**Buildings**

# LAA Permit Department of Buildings

Permit Number: 240050617-LAA

Issued: 03/04/2014  
3:33 PM

Expires: 03/04/2015

Address: BRONX 200 EAST 205TH STREET

Issued to: STEVE SIBRIZZI

Floors: CEL

Business: CASTLE OIL CORPORATION

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

Licensee No: O - 005274

CONVERTING FROM #6 FUEL OIL TO #4 FUEL OIL. DISCONNECT AND REMOVE OIL PREHEATER. INSTALL  
2" ANTI-SIPHON VALVE ON EXISTING EQUIPMENT. NO CHANGE IN FIRE RATING. DEP APPLICATION  
#CA231297P. ASBESTOS CONTROL#2115093

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 01/19/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.