



Buildings



LAA Permit Department of Buildings

Permit Number: 240051616-LAA

Issued: 03/14/2014
12:50 PM

Expires: 03/14/2015

Address: BRONX 930 SHERIDAN AVENUE

Issued to: PETER CAPUTO

Business: LEARDON BOILER WORKS.INC

Floors: CEL

Licensee No: 0 - 005260

Description of Work: Oil: OIL WORK - FUEL GRADE CHANGE

CHANGE GRADE OF OIL FROM #6 TO #4. INSTALL ANTI-SYPHON DEVICE ON SUPPLY LINE. NO CHANGE IN FIRING RATE. REMOVE/DISCONNECT PRIMARY PRE-HEATER. NYC DEP #CA205786R.

Emergency Telephone Day or Night: 311

Borough Commissioner:

A handwritten signature in black ink, likely of the Borough Commissioner.

Commissioner of Buildings:

A handwritten signature in black ink, likely of the Commissioner of Buildings.

This permit copy created on 11/26/2025 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.