



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 240060697-LAA

Issued: 06/09/2014  
11:13 AM

Expires: 06/09/2015

Address: BRONX 254 EAST 202 STREET

Issued to: BERNARD BAUER

Floors: CEL

Business: G. BAUER, INC

Licensee No: 0 - 005353

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

CHANGE FUEL GRADE FROM #6 TO #4. A PRE-HEATER WILL BE REMOVED AND AN ANTI-SYPHON VALVE FOR EXISTING EQUIPMENT WILL BE INSTALLED. THERE IS NO CHANGE IN FIRING RATE. DEP INSTALLATION #CB490603Y. ACP5 FILED UNDER #200864822.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 05/11/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.