



**Buildings**

# **LAA Permit Department of Buildings**

Permit Number: **240065674-LAA**

Issued: **07/22/2014  
3:02 PM**

Expires: **07/22/2015**

Address: **BRONX 3604 OLINVILLE AVENUE**

Issued to: **BERNARD BAUER**

Floors: **CEL**

Business: **G. BAUER, INC**

Licensee No: **O - 005353**

Description of Work: **oil: OIL WORK - FUEL GRADE CHANGE**

**CHANGE FUEL GRADE FROM #6 TO #2. A PRE-HEATER WILL BE REMOVED AND AN ANTI-SIPHON VALVE FOR EXISTING EQUIPMENT WILL BE INSTALLED. THERE IS NO CHANGE IN FIRING RATE. DEP INSTALLATION #CA271782. ACP5 FILED UNDER #200380916.**

---

Emergency Telephone Day or Night: **311**

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 02/04/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.