



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 240067592-LAA

Issued: 08/04/2014  
10:16 AM

Expires: 08/04/2015

Address: BRONX 3060 HULL AVENUE

Issued to: BERNARD BAUER

Floors: CEL

Business: G. BAUER, INC

Licensee No: O - 005353

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

CHANGE FUEL GRADE FROM #6 TO #2. A PRE-HEATER WILL BE REMOVED AND AN ANTI-SIPHON VALVE FOR EXISTING EQUIPMENT WILL BE INSTALLED. THERE IS NO CHANGE IN FIRING RATE. DEP INSTALLATION #CB045413H. ACP5 FILED UNDER #200233149. CONVERSION WILL BE COMPLETED BY JUNE 30, 2015.\_D.S.

1031MAIL

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings: Acting Commissioner of Buildings

*This permit copy created on 01/18/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.