



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 240069420-LAA

Issued: 08/19/2014  
2:37 PM

Expires: 08/19/2015

Address: BRONX 2191 BOLTON STREET

Issued to: MICHAEL BENDJOUYA

Floors: BAS

Business: C C CONTROLLED COMBUSTION

Licensee No: O - 001509

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

CHANGE GRADE OF FUEL FROM #6 OIL TO #2 OIL. WE WILL REMOVE THE PRE-HEATERS AND INSTALL ANTI-SIPHON VALVES FOR THE EXISTING EQUIPMENT. THERE IS NO CHANGE IN THE FIRING RATE.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 03/30/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.