



LAA Permit Department of Buildings

Permit Number: 240070490-LAA

Issued: 08/26/2014
12:28 PM

Expires: 08/26/2015

Address: BRONX 2676 GRAND CONCOURSE

Issued to: KEITH R CAPPUCCIO

Floors: CEL

Business: DMT PLUMBING&HEATING CORP

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

Licensee No: O - 005355

CHANGE GRADE OF FUEL FROM #6 TO #2. REMOVE PRE-HEATER AND INSTALL ANTI-SIPHON VALVE. NO
CHANGE IN FIRING RATE DEP INSTALLATION #CB066910. EXISTING EQUIPMENT FILED UNDER
#220061073.

Emergency Telephone Day or Night: 311

Borough Commissioner:

A handwritten signature in black ink, appearing to read 'John J. ...'.

Commissioner of Buildings:

A handwritten signature in black ink, appearing to read 'Craig R. ...'.

This permit copy created on 01/19/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.