



Buildings

LAA Permit Department of Buildings

Permit Number: **240073022-LAA**

Issued: **09/18/2014
11:30 AM**

Expires: **09/18/2015**

Address: **BRONX 666 EAST 224 STREET**

Issued to: **BERNARD BAUER**

Floors: **CEL**

Business: **G. BAUER, INC**

Licensee No: **O - 005353**

Description of Work: **oil: OIL WORK - FUEL GRADE CHANGE**

CHANGE FUEL GRADE FROM #6 TO #4. A PER-HEATER WILL BE REMOVED AND AN ANTI-SIPHON VALVE FOR EXISTING EQUIPMENT WILL BE INSTALLED. THERE IS NO CHANGE IN FIRING RATE. DEP INSTALLATION #CA175584Y.

Emergency Telephone Day or Night: **311**

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 02/10/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.