



Buildings



LAA Permit Department of Buildings

Permit Number: 240083100-LAA

Issued: 12/05/2014
4:05 PM

Expires: 12/05/2015

Address: BRONX 3425 GATES PLACE

Issued to: MARVIN WASOFF

Floors: CEL

Business: WASOFF PLBG. & UTL.CO INC

Licensee No: 0 - 005257

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

CHANGE FUEL GRADE FROM #6 OIL TO #4 OIL. INSTALL AN ANTI-SYPHON DEVICE ON SUPPLY LINE. NO CHANGE IN FIRING RATE. REMOVE/DISCONNECT PRIMARY PRE-HEATER. NYC DEP # CA345388

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/22/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.