



Buildings



LAA Permit Department of Buildings

Permit Number: 240096338-LAA

Issued: 04/21/2015
5:40 PM

Expires: 07/28/2017

Address: BRONX 200 BAYCHESTER AVENUE

Issued to: JOHN C BOWER

Business: ABCO PEERLESS SPRNK CORP

Floors: 003

Licensee No: F - 000177

Description of Work: Fire Suppression: FIRE SUPPRESSION WORK

INSTALLATION OF (2) NEW SPRINKLER HEADS USING APPROX 16'-0" OF 1" PIPING AND REARRANGE (12) EXISTING SPRINKLER HEADS USING APPROX 90'-0" OF 1" PIPING. NO CHANGE TO USE, OCCUPANCY OR EGRESS. STORE LOCATED IN STRIP MALL. THE SYSTEM WILL BE DOWN FOR LESS THAN 4 HOURS.

R0428/6MD/A0513/6MD A0714/6MD R0714/6MD

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 09/16/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.