



Buildings



LAA Permit Department of Buildings

Permit Number: 240098087-LAA

Issued: 05/06/2015
1:20 PM

Expires: 05/06/2016

Address: BRONX 3230 CRUGER AVENUE

Issued to: MICHAEL S KAPLAN

Floors: BAS

Business: MICHAEL S. KAPLAN

Licensee No: O - 005128

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

NOTICATION OF FUEL GRADE CHANGE FROM #6 OIL TO # 4 OIL.WE WILL DEMOE REMOVESIDEWALL HEATERS .WE WILL INSTALL ANTI-SYPHON AND SHUT OFF VALVES ON THE OIL SUPPLY LINE TO EXISTING BOILER AND BURNER.NO CHANGE IN OCCUPANCY OR EGRESS.NO CHANGE IN FIRING RATEJOB WILL BE COMPLETED BY JUNE 30TH 2015.CA214271

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 02/02/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.