



Buildings

LAA Permit Department of Buildings

Permit Number: 240099834-LAA

Issued: 05/19/2015
2:46 PM

Expires: 05/19/2016

Address: BRONX 1591 FULTON AVENUE

Issued to: SCOTT KREITZER

Floors: CEL

Business: CASA MECHANICAL CO. INC

Description of Work: Plumbing: GAS PLUMBING WORK

Licensee No: P - 001294

Gas Usage(s): Heat

REPLACE EXISTING (2) GAS FIRED HOT WATER BOILERS WITH (2) CROWN BOILERS MOD#16H-340 ETL LISTED #J99021003-005 INPUT BTU OF 340,000 OUTPUT BTU OF 275,000 BOTH UNITS WILL BE VENTED THROUGH EXISTING CHIMNEY. RECONNECT TO EXISTING GAS PIPING. NO GAS TEST REQD. NYC BOILER #14411-03 & 04

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/21/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.